



Retail Market Permit Inspection Report

Kings County Department of Public Health
Environmental Health Services

460 Kings County Dr., Suite 101 & 102 Hanford CA 93230

Phone - 559-584-1411 Fax - 559-584-6040

Internet - <https://www.kcdph.com/ehs>

INSPECTION REPORT

FOOD VENDING PERMIT -RM6 (>15000)

Facility Name		Facility Address		City/State		Zip Code	
SAVE MART #73		105 W HANFORD-ARMONA RD		LEMOORE, CA		93245	
Owner/Operator		Facility Phone No.		Inspection ID		Inspection Result	
SAVE MART SUPERMARKETS		5599240594		29356		Pass	
Inspector Name		Inspection Date	Purpose of Inspection		Permit License		Expiration Date
Isaac Coria		2/1/2024	Routine Inspection		PR0003430		12/1/2025

An inspection of your facility revealed the following violations of the California Health and Safety Code and/or California Code of Regulations. A reinspection may occur at any time to verify correction of these violations. Please note the date of correction as listed per violation.

NVO = No Violation Observed OUT = Out of Compliance N/A = Not Applicable COS = Corrected On Site UD = UD



Retail Market Permit Inspection Report

Kings County Department of Public Health
Environmental Health Services

460 Kings County Dr., Suite 101 & 102 Hanford CA 93230

Phone - 559-584-1411 Fax - 559-584-6040

Internet - <https://www.kcdph.com/ehs>

INSPECTION REPORT

FOOD VENDING PERMIT -RM6 (>15000)

Overall Inspection Comment:

Observations from todays inspection:

Hand washing station water temperature reached 100F and was fully stocked in food prep area.

Restroom sink did not reach 100F, please ensure that it is capable of reaching 100F.

Three compartment sink water reached 120F and was at 200 ppm for quat.

Cold storage units were below 40F. Hot holding food was recorded above 135F, except for rotisserie chicken, it was around 115F, but within 4hr window.

All food was 6 inches from the floor but small amounts of debris was present in food prep areas.

Observed one spider hanging from bakery hood and small grease accumulation in the other hood, please ensure area is regularly upkept.

Floor sinks in bakery section did not have an air gap, please ensure piping has at least a 1in gap from floor sink .

Canned and sealed products were in good condition and within Best Buy date.

Food handler certificate for managers was shown, Charles Williams, exp 3/4/28.

ATTENTION: There are a total of 0 item(s) marked above in violation. Total Major violations are 0.

Signatures

Received By:

Inspected By:

Inspector Name: **Isaac Coria**

Title: **Environmental Health Officer**

Date: **2/1/2024**

Email: **Isaac.Coria@co.kings.ca.us**

Phone: