



**Rose Mary Rahn**  
Director

**Milton Teske, M.D.**  
Health Officer

To promote and protect the health and well-being of Kings County residents through education, prevention, and intervention.



---

## **Kings County Fire Department Requirements for Cooking at Temporary Events**

1. Cooking equipment shall be protected from the public.
2. Any gas fired deep fryer must have a Type K fire extinguisher within 30 feet of cooking operations. Wood fired cooking operations shall have a 2A-40BC rated fire extinguisher within 30 feet of cooking operations.
3. Fuel containers shall be stored away from the cooking operations with the exception of the one that is providing fuel for the appliance during cooking operations and it shall be protected in a manner that prevents it from being knocked over.
4. Fuel containers in use shall be installed in a manner that protects them from radiant heat from the appliance to prevent activation of the relief valve.
5. Cooking operations shall not be permitted within 30 feet of combustible vegetation and combustible waste shall not be allowed to accumulate within 30 feet of cooking operations.
6. Vehicles shall not be parked within 30 feet of cooking equipment.

For further information please contact Kings County Fire Department, 559-852-2881 or Hanford City Fire Department, (559) 584-9276.